

Certificate

Registration No.: PV 50166924

Page 2

Report No.: 12605858 003

License Holder:

LG Electronics Inc.

191-1, Gongdan-dong
Gumi, Gyeongsangbuk-do
730-030, Rep. of Korea

Product:

PV Module

Addition

Type: LGxxxM1W-G1, LGxxxM1C-G1 (60 cells)
LGyyyP1W-G1, LGyyyP1C-G1 (60 cells)
xxx = 220, 225, 230, 235, 240, 245, 250, 255 or 260
yyy = 210, 215, 220, 225, 230, 235, 240, 245 or 250

Manufacturing Plant:

LG Electronics Inc.

191-1, Gongdan-dong
Gumi, Gyeongsangbuk-do
730-030, Rep. of Korea

LGxxxM9W-G1, LGxxxM9C-G1 (54 cells)
LGyyyP9W-G1, LGyyyP9C-G1 (54 cells)
xxx = 180, 185, 190, 195, 200, 205, 210, 215 or 220
yyy = 180, 185, 190, 195, 200, 205 or 210

Basis:



**IEC 61215:2005
EN 61215:2005**

"Crystalline silicon terrestrial
photovoltaic (PV) modules - Design
qualification and type approval"



Factory Inspection

To document the consistent quality of
the product factory inspections are
performed periodically.



- **Periodic inspection**
- **Qualified, IEC 61215**
- **Safety tested, IEC 61730**

Remarks:

- Additional type designations see above.
- The details of the factory inspection are documented in report no. 13500182.
- Mechanical Load was performed at 5400 Pa.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid for 5 years from the date of issue stated on page 1.



Certification body



Dipl.-Ing. S. Hartter

Yokohama, 02 February 2010

Certificate

Registration No.: PV 50166925

Page 2

Report No.: 12605858 004

License Holder:

LG Electronics Inc.

191-1, Gongdan-dong
Gumi, Gyeongsangbuk-do
730-030, Rep. of Korea

Product:

PV Module

Addition

Type: LGxxxM1W-G1, LGxxxM1C-G1 (60 cells)
LGyyyP1W-G1, LGyyyP1C-G1 (60 cells)
xxx = 220, 225, 230, 235, 240, 245, 250, 255 or 260
yyy = 210, 215, 220, 225, 230, 235, 240, 245 or 250

Manufacturing Plant:

LG Electronics Inc.

191-1, Gongdan-dong
Gumi, Gyeongsangbuk-do
730-030, Rep. of Korea

LGxxxM9W-G1, LGxxxM9C-G1 (54 cells)
LGyyyP9W-G1, LGyyyP9C-G1 (54 cells)
xxx = 180, 185, 190, 195, 200, 205, 210, 215 or 220
yyy = 180, 185, 190, 195, 200, 205 or 210

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"



- Periodic inspection
- Qualified, IEC 61215
- Safety tested, IEC 61730

- Factory Inspection**
To document the consistent quality of the product factory inspections are performed periodically.

Remarks:

- Additional type designations see above.
- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 13500182.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid for 5 years from the date of issue stated on page 1.



Certification body



Dipl.-Ing. S. Hartter

Yokohama, 02 February 2010